

DOCUMENT 00 91 13
ADDENDUM #2

DATE: November 29, 2011

FROM: Rettler Corporation
3317 Business Park Drive
Stevens Point, Wisconsin 54481

TO: *Prospective Bidders*

RE: Addendum #2 to the Bidding Documents for the

**VERONA HIGH SCHOOL
TRACK AND FIELD REDEVELOPMENT PROJECT
The Verona Area School District
Verona, Wisconsin**

This addendum forms a part of the Contract Documents and modifies the original Contract Documents dated November 9, 2011 as noted below. Acknowledge receipt of this Addendum by inserting the number and issue date of this addendum in the blank space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

CHANGES TO SPECIFICATIONS

SECTION 32 10 00 – HARD SURFACE BASE AND PAVING

REVISION: ADDENDUM #1 required 95% compaction of the installed subbase and asphalt surface. Delete the Addendum #1 reference to the installed subbase and asphalt surface compaction requirements and replace with the following;

“The CONTRACTOR shall provide compaction test results of 95% or greater for the installed subbase and 91.5% for the asphalt surfaces”

SECTION 32 18 13 – SYNTHETIC TURF

REVISION: PART THREE – EXECUTION Base and Finish Drainage Stone (for use on synthetic turf subgrade). Add the following to Line 13, page 32 18 13-8;

“The in-place compacted depth of base stone shall be four (4) inches. The in-place, compacted depth of finish stone shall be two (2) inches”.

REVISION: PART THREE – EXECUTION, Perimeter Curb and Nailer. Add the following to Line 20, page 32 18 13-8;

“Attach nailer to slot drain encasement on track side as described above”

SECTION 32 50 00 – MODULAR RETAINING WALL

REVISION: Delete the entire Section and replace with the attached, revised SECTION 32 50 00

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54

CHANGES TO DRAWINGS

SHEET C5.0 – SITE STORM SEWER PLAN

CLARIFICATION:

There is no north arrow or scale shown on original bid documents. North shall be oriented to the right of the sheet and scale shall read 1" = 30 ft.

SHEET C6.0 – SITE UTILITY PLAN

CLARIFICATION:

The original bid documents incorrectly reference the scale as 1" = 40 ft. Revise the scale to read 1"=30ft.

SHEET C6.0 – SITE SANITARY SEWER PLAN

CLARIFICATION:

The original bid documents incorrectly reference the scale as 1" = 40 ft. Revise the scale to read 1"=30ft.

SHEET P2 – PLUMBING WATER PIPING

CLARIFICATION:

This plan sheet contains a chart in the upper left corner entitled "Water Sizing Chart". Some of the bid documents may have been issued with Sheet P2 missing this chart. The chart is provided below and is part of Sheet P2 and the Bid Documents.

Water Sizing Chart										
ID	DESCRIPTION	MANUFACTURER	MODEL #	#FIX	HOT	COLD	H & C	TOTAL HOT	TOTAL COLD	TOTAL H & C
WC-1	A.D.A. TOILET	ZURN	ZER-6000-AV-WS1	7	0	4.5	6.5	0	45.5	45.5
WC-2	TOILET	ZURN	ZER-6000-AV-WS1	2	0	4.5	6.5	0	13	13
UR-1	A.D.A. URINAL	ZURN	ZER-8003-AV-WS1	1	0	2	2	0	2	2
UR-2	URINAL	ZURN	ZER-8003-AV-WS1	4	0	2	2	0	8	8
L-1	2 STATION WASH FOUNTAIN	ACORN	3M02-1-SO-BAT	4	1	1	2	4	4	8
DF-1	DRINKING FOUNTAIN	ACORN	2012-1-ADA-BC-EB	2	0	0.25	0.25	0	0.5	0.5
HS-1	HAND WASH SINK	SYMMONS	88080	1	0.5	0.5	1	0.5	0.5	1
MB-1	MOP SINK	CHICAGO/WATTS	887 RC / BC	1	2	2	3	2	2	3
HB	HOSE BIB (1/2")	WOODFORD	824	2	0	3	3	0	6	6
WH	WATER HEATER	BRADFORD WHITE	M250P608	1	0	0	0	0	0	0
	TOTAL			25				6.5	81.5	87

(END OF SECTION)